

No.	Properties	Unit	Result	Ref. Test Method
1	Density @ 15°C	Kg/m <sup>3</sup>	<b>775 min</b>	ASTM D-1298
2	I.B.P	°C	<b>142-158</b>	ASTM D86
3	10%	°C	<b>158 min</b>	ASTM D86
4	50%	°C	<b>179 max</b>	ASTM D86
5	90%	°C	<b>194 max</b>	ASTM D86
6	Dry point	°C	<b>198 max</b>	ASTM D86
7	Residue	vol%	<b>1.5 max</b>	ASTM D86
8	Saybolt color	-	<b>25 min</b>	ASTM D156
9	Odour	-	<b>Merchantable</b>	-
10	Flash point tag	°C	<b>38 min</b>	ASTM D56
11	Corrosion 3hr @ 100°C	-	<b>1a</b>	ASTM D130
12	Total Sulphur	Wt%	<b>0.1 max</b>	ASTM D5453
13	Doctor test	-	<b>Negative</b>	ASTM D4952
14	Aromatic content	vol%	<b>20 max</b>	ASTM D1319
15	Gum Existent	mg/100ml	<b>5 max</b>	ASTM D381
16	Neutrality	-	<b>Pass</b>	BS.245
17	Acidity of Residue	-	<b>Pass</b>	ASTM D1093

